

DEQ Monitoring Well Data from Individual Properties

System Type	Point ID	DEQ Well ID	Sample Date	BOD-5 (mg/L)	TSS (mg/L)	NH4-N (mg/L)	Nitrate-Nitrite as N (mg/L)	TKN (mg/L)	TN (mg/L)	Chloride (mg/L)	Dissolved Oxygen (mg/L)
FAST	MW	2054	9/23/2003			0.01	4.44	0.10	4.54	2.90	6.30
Bottomless Sand Filter	MW	2205	3/11/2003			0.05	4.41	0.10	4.51	8.30	6.00
Amphidrome	MW	2129	11/3/2004			0.02	4.33	0.10	4.43	12.00	7.90
Bottomless Sand Filter	MW	2033	6/10/2003			0.01	4.28	0.10	4.38	10.00	7.80
Pressure	MW	2081	3/21/2001	0.00	6.00	0.00	4.25	0.10	4.35	4.70	8.30
NITREX	MW Drain	2070	1/28/2002	0.50	0.50	0.00	4.20	0.10	4.30	11.00	2.20
NiteLess	MW	2133	9/21/2001			0.04	4.14	0.10	4.24	22.00	8.10
Amphidrome	MW	2159	4/21/2003			0.01	4.07	0.10	4.17	7.90	9.10
Puraflo	MW	2168	12/7/2004			0.04	3.64	0.40	4.04	22.00	9.20
NiteLess	MW	2172	10/28/2003			0.01	3.83	0.20	4.03	15.00	8.00
Nayadic	MW	2103	2/10/2003			0.01	3.42	0.30	3.72	6.90	8.80
Pressure	MW	2037	10/18/2004			0.01	3.41	0.30	3.71	21.00	3.30
Innovative Trench Design B	MW Drain	2181	2/19/2003	0.50	50.00	0.08	3.61	0.10	3.71	8.50	7.10
Innovative Trench Design B	MW	2196	10/14/2003			0.01	3.48	0.10	3.58	4.30	8.50
Biokreisel	MW	2056	3/20/2001	0.00	3.00	0.00	3.38	0.20	3.58	15.00	5.30
FAST	MW	2060	3/11/2003			0.04	3.13	0.40	3.53	14.00	9.40
NITREX	MW	2065	3/24/2003			0.01	3.35	0.10	3.45	18.00	5.40
Advantex RX-30	MW	2011	9/2/2003			0.01	3.05	0.40	3.45	18.00	4.40
Biokreisel	MW	2217	12/9/2002			0.02	3.17	0.20	3.37	10.00	1.00
Innovative Trench Design B	MW	2179	4/15/2003			0.01	3.26	0.10	3.36	8.80	9.10
NITREX	MW	2067	11/18/2003			0.01	2.98	0.10	3.08	5.80	3.40
Bottomless Sand Filter	MW	2027	9/16/2003			0.01	2.94	0.10	3.04	2.90	7.50
Bottomless Sand Filter	MW	2206	9/10/2002			0.01	2.90	0.10	3.00	9.30	8.30
Amphidrome	MW	2110	10/23/2002			0.01	2.83	0.10	2.93	13.00	0.10
IDEA BESTEP	MW Drain	2145	3/17/2003	0.50	1.00	0.05	2.51	0.10	2.61	7.00	6.90
NiteLess	MW	2131	5/14/2002			0.01	2.38	0.10	2.48	69.00	5.40
Advantex AX-20	MW	2192	10/4/2004			0.01	2.30	0.10	2.40	5.10	7.50
FAST	MW Drain	2026	11/5/2003	0.50	0.50	0.01	2.08	0.30	2.38	23.00	5.70
Standard	MW	2218	9/8/2003			0.01	2.27	0.10	2.37	3.90	4.40
FAST	MW	2024	3/18/2003			0.03	2.24	0.10	2.34	5.10	2.70
Standard	MW	2039	3/5/2002			0.00	2.10	0.10	2.20	4.90	6.50
Standard	MW	2021	10/19/2004			0.01	2.04	0.10	2.14	1.00	8.30
Bottomless Sand Filter	MW	2213	9/17/2003			0.70	1.40	0.70	2.10	1.90	4.70
Advantex AX-20	MW	2184	10/28/2002			2.00	0.02	2.00	2.02	17.00	0.30
Pressure	MW	2036	10/18/2004			0.01	1.87	0.10	1.97	4.20	2.60
Puraflo	MW	2148	5/13/2002			0.01	1.83	0.10	1.93	100.00	3.30
IDEA BESTEP	MW	2142	8/26/2003			0.01	1.61	0.30	1.91	3.90	7.30
Advantex AX-20	MW	2190	10/4/2004			0.01	1.74	0.10	1.84	2.10	8.80
FAST	MW	2061	3/12/2002			0.10	0.20	1.60	1.80	17.00	6.10
Amphidrome	MW Drain	2112	12/3/2002	0.50	0.50	0.01	1.63	0.10	1.73	10.00	0.40
Bottomless Sand Filter	MW	2212	6/17/2003			0.06	1.56	0.10	1.66	4.10	5.10
NITREX	MW Drain	2211	11/17/2003	0.50	0.50	0.01	1.55	0.10	1.65	7.50	6.70
IDEA BESTEP	MW	2144	5/20/2003			0.03	1.55	0.10	1.65	67.00	7.70
Standard	MW	2220	6/17/2003			0.02	1.52	0.10	1.62	0.80	6.50
Advantex RX-30	MW	2012	6/11/2003			0.01	1.61	0.10	1.61	5.60	9.00
FAST	MW	2051	3/24/2003			0.01	1.50	0.10	1.60	2.00	7.50
IDEA BESTEP	MW	2176	4/29/2002			0.01	1.49	0.10	1.59	4.80	6.00
Pressure	MW	2043	9/24/2003			0.01	1.43	0.10	1.53	1.60	8.00
IDEA BESTEP	MW	2143	8/26/2003			0.01	1.19	0.30	1.49	47.00	7.30
Innovative Trench Design B	MW	2180	11/17/2004			0.03	1.34	0.10	1.44	2.50	8.30
EnviroServer	MW	2097	3/24/2003			0.01	1.23	0.10	1.33	4.80	0.10
Constructed Wetlands	MW	2107	12/8/2004			0.01	1.22	0.10	1.32	62.00	7.20
Innovative Trench Design A	MW	2032	11/2/2004			0.01	1.16	0.10	1.26	14.00	5.60
Bottomless Sand Filter	MW	2028	3/19/2002			0.00	0.90	0.30	1.20	10.00	7.00
Standard	MW	2072	3/18/2002			0.00	1.10	0.10	1.20	0.70	8.40
Bottomless Sand Filter	MW	2029	6/18/2002			0.03	1.09	0.10	1.19	2.80	8.40
Biokreisel	MW	2057	12/9/2002			0.01	1.09	0.10	1.19	3.50	5.30
Constructed Wetlands	MW Drain	2157	3/15/2004			0.01	1.07	0.10	1.17	6.30	6.80
NITREX	MW	2069	12/17/2002			0.01	1.06	0.10	1.16	1.60	3.10
Advantex AX-20	MW	2183	8/6/2002			0.88	0.01	1.10	1.11	5.50	0.30
Advantex AX-20	MW	2050	5/14/2002			0.02	0.63	0.40	1.03	2.60	7.70
Biokreisel	MW	2004	3/4/2002			0.20	0.30	0.70	1.00	11.00	8.70
Innovative Trench Design B	MW	2163	10/1/2002			0.07	0.83	0.10	0.93	5.60	6.30
Bottomless Sand Filter	MW	2083	3/13/2002			0.60	0.00	0.80	0.80	2.00	7.60
Standard	MW	2041	3/5/2002			0.00	0.70	0.10	0.80	1.60	8.40
Standard	MW	2071	6/18/2002			0.01	0.68	0.10	0.78	1.00	7.40
Pressure	MW Drain	2038	4/12/2004			0.01	0.65	0.10	0.75	32.00	3.30
Advantex AX-20	MW	2182	10/28/2002			0.45	0.02	0.70	0.72	15.00	0.10
IDEA BESTEP	MW Drain	2177	8/4/2003			0.01	0.61	0.10	0.71	1.40	8.00
EnviroServer	MW	2099	9/24/2002			0.01	0.61	0.10	0.71	3.00	0.70
FAST	MW	2052	3/26/2002			0.00	0.60	0.10	0.70	1.00	7.10
Constructed Wetlands	MW	2092	2/19/2002			0.00	0.60	0.10	0.70	6.00	0.70
Advantex RX-30	MW	2012	6/12/2002			0.01	0.53	0.10	0.63	6.90	9.00
Constructed Wetlands	MW	2155	8/26/2002			0.47	0.01	0.60	0.61	26.00	0.40
Advantex AX-20	MW Drain	2185	10/28/2002	0.50	3.00	0.59	0.01	0.60	0.61	0.70	0.20
FAST	MW	2025	3/4/2002			0.00	0.45	0.10	0.55	2.30	6.30
Nayadic	MW	2119	9/27/2004			0.01	0.44	0.10	0.54	2.00	1.30
EnviroServer	MW	2098	12/19/2001			0.00	0.35	0.10	0.45	4.20	0.10
EnviroServer	MW	2007	6/25/2002			0.02	0.01	0.40	0.41	4.80	9.80

DEQ Monitoring Well Data from Individual Properties

System Type	Point ID	DEQ Well ID	Sample Date	BOD-5 (mg/L)	TSS (mg/L)	NH4-N (mg/L)	Nitrate-Nitrite as N (mg/L)	TKN (mg/L)	TN (mg/L)	Chloride (mg/L)	Dissolved Oxygen (mg/L)
Innovative Trench Design A	MW	2135	7/15/2003			0.01	0.20	0.20	0.40	0.80	5.70
Pressure	MW	2035	6/3/2002			0.06	0.00	0.40	0.40	4.40	4.20
IDEA BESTEP	MW	2152	4/29/2002			0.08	0.00	0.40	0.40	3.00	0.05
Advantex AX-20	MW	2022	5/14/2002			0.01	0.28	0.10	0.38	5.40	6.90
Nayadic	MW Drain	2120	9/27/2004			0.01	0.25	0.10	0.35	2.20	0.30
Innovative Trench Design A	MW	2136	10/6/2003			0.05	0.03	0.30	0.33	8.50	3.10
Biokreisel	MW	2015	6/2/2003			0.01	0.02	0.30	0.32	2.00	7.00
NiteLess	MW	2170	10/28/2003			0.03	0.02	0.30	0.32	5.40	0.10
FAST	MW	2053	3/26/2002			0.00	0.20	0.10	0.30	0.70	2.00
FAST	MW	2023	6/6/2001	0.00	4.00	0.00	0.14	0.10	0.24	0.00	1.10
NiteLess	MW	2171	10/28/2003			0.01	0.14	0.10	0.24	6.20	0.70
Biokreisel	MW	2016	3/4/2003			0.03	0.13	0.10	0.23	1.20	6.70
EnviroServer	MW	2008	9/24/2002			0.03	0.12	0.10	0.22	8.90	7.60
Constructed Wetlands	MW	2154	2/24/2003			0.24	0.02	0.20	0.22	2.00	0.40
Innovative Trench Design B	MW Drain	2165	2/4/2004			0.18	0.01	0.20	0.21	5.00	0.20
NITREX	MW Drain	2066	12/26/2000	1.00	57.00	0.02	0.11	0.10	0.21	3.40	0.50
Constructed Wetlands	MW	2156	12/7/2004			0.01	0.11	0.10	0.21	4.50	2.80
Innovative Trench Design A	MW	2122	7/15/2002			0.01	0.10	0.10	0.20	4.00	5.00
IDEA BESTEP	MW	2150	2/24/2003			0.06	0.09	0.10	0.19	2.00	0.10
Bottomless Sand Filter	MW	2086	9/17/2003			0.01	0.08	0.10	0.18	1.60	5.90
Innovative Trench Design A	MW	2115	3/31/2003			0.04	0.08	0.10	0.18	3.60	6.50
Puraflo	MW	2146	5/13/2002			0.04	0.07	0.10	0.17	6.50	7.60
IDEA BESTEP	MW	2151	2/24/2003			0.05	0.06	0.10	0.16	2.20	0.20
Standard	MW	2020	6/24/2003			0.03	0.05	0.10	0.15	1.40	7.00
Innovative Trench Design A	MW Drain	2116	8/19/2003	0.50	2.00	0.05	0.04	0.10	0.14	15.00	0.10
Innovative Trench Design B	MW	2162	11/16/2004			0.03	0.03	0.10	0.13	2.30	6.50
Innovative Trench Design A	MW	2113	3/31/2003			0.05	0.03	0.10	0.13	3.30	0.20
IDEA BESTEP	MW	2088	2/24/2003			0.13	0.02	0.10	0.12	4.50	0.10
IDEA BESTEP	MW Drain	2153	8/26/2003	0.50	0.50	0.08	0.02	0.10	0.12	4.00	0.30
Innovative Trench Design A	MW	2114	9/29/2003			0.04	0.02	0.10	0.12	7.90	0.05
Innovative Trench Design B	MW	2164	9/29/2003			0.17	0.01	0.10	0.11	6.20	0.10
Puraflo	MW	2147	11/4/2002			0.21	0.01	0.10	0.11	5.60	0.05
Nayadic	MW	2118	9/27/2004			0.10	0.01	0.10	0.11	2.50	0.20